

INSTALLATION NOTES:

- ONE (1) INSTALLATION ANCHOR IS REQUIRED AT EACH ANCHOR LOCATION, UNLESS OTHERWISE SHOWN.
- THE NUMBER OF INSTALLATION ANCHORS DEPICTED IS THE MINIMUM NUMBER OF ANCHORS TO BE USED FOR PRODUCT INSTALLATION OF THE MAXIMUM SIZE LISTED.
- INSTALL INDIVIDUAL INSTALLATION ANCHORS WITHIN A TOLERANCE OF ±1/2 INCH BASED ON QUANTITIES IN DP CHARTS NOT TO EXCEED THE DEPICTED LOCATION & SPACING IN THE ANCHOR LAYOUT DETAILS (I.E., WITHOUT CONSIDERATION OF TOLERANCES). TOLERANCES ARE NOT CUMULATIVE FROM ONE INSTALLATION ANCHOR TO THE NEXT
- SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM(S). MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4 INCH AT THE HEAD AND SILL AND 3/8 INCH AT THE JAMBS. SHIM WHERE SPACE OF 1/16 INCH OR GREATER OCCURS. SHIM(S) SHALL BE CONSTRUCTED OF HIGH DENSITY PLASTIC OR BETTER.
- THROUGH FRAME:** FOR INSTALLATION INTO WOOD FRAMING USE #10 WOOD SCREWS OF SUFFICIENT LENGTH TO ACHIEVE 1 1/2" MINIMUM EMBEDMENT INTO WOOD SUBSTRATE.
- THROUGH FRAME:** FOR INSTALLATION THROUGH 1X BUCK TO CONCRETE/MASONRY, OR DIRECTLY INTO CONCRETE/MASONRY, USE 1/4" DIAMETER ITW TAPCONS, ELCO ULTRACON, ELCO CRETE-FLEX OR HILTI KWIK-CON II OF SUFFICIENT LENGTH TO ACHIEVE 1 1/4" MINIMUM EMBEDMENT.
- THROUGH FRAME:** FOR INSTALLATION INTO METAL STUD OR APPROVED MULLION USE #10 GR. 5 SELF TAPPING SCREWS OF SUFFICIENT LENGTH TO ACHIEVE A MINIMUM OF 3 THREADS PENETRATION BEYOND METAL FRAME SUBSTRATE.
- CLIPS SHALL BE FASTENED TO THE WINDOW FRAME WITH (2) #8 X 5/8" SCREWS. CLIPS ARE 20 GAUGE (0.063" THICKNESS) F_y=33 KSI MIN STEEL WITH OVERALL DIMENSIONS OF 1.5" WIDE, 7.813" ALONG THE LONG LEG, AND 1.942" ALONG THE SHORT LEG.
- CLIP ANCHOR:** FOR INSTALLATION INTO METAL STUD USE (2) #8 GR. 5 SELF-TAPPING SCREWS PER CLIP OF SUFFICIENT LENGTH TO ACHIEVE 3 THREADS MINIMUM PENETRATION BEYOND THE METAL STRUCTURE.
- CLIP ANCHOR:** FOR INSTALLATION INTO WOOD FRAMING USE (2) #8 WOOD SCREWS PER CLIP OF SUFFICIENT LENGTH TO ACHIEVE 1 1/2 INCH MINIMUM EMBEDMENT INTO WOOD SUBSTRATE.
- NAIL FIN:** FOR INSTALLATION INTO WOOD FRAMING USE #8 WOOD SCREWS OR USE 10D COMMON NAIL OR 11 GAUGE ROOFING NAIL PER LOCATION OF SUFFICIENT LENGTH TO ACHIEVE 1 1/2 INCH MINIMUM EMBEDMENT INTO WOOD SUBSTRATE.
- NAIL FIN:** FOR INSTALLATION INTO METAL STUD OR APPROVED MULLION USE #8 GR. 5 SELF TAPPING SCREWS OF SUFFICIENT LENGTH TO ACHIEVE A MINIMUM OF 3 THREADS PENETRATION BEYOND METAL FRAME SUBSTRATE.
- MINIMUM EMBEDMENT AND EDGE DISTANCE EXCLUDE WALL FINISHES, INCLUDING BUT NOT LIMITED TO STUCCO, FOAM, BRICK VENEER, AND SIDING.
- INSTALLATION ANCHORS AND ASSOCIATED HARDWARE MUST BE MADE OF CORROSION RESISTANT MATERIAL OR HAVE A CORROSION RESISTANT COATING.
- FOR GROUT FILLED BLOCK, DO NOT INSTALL INSTALLATION ANCHORS INTO MORTAR JOINTS. EDGE DISTANCE IS MEASURED FROM FREE EDGE OF BLOCK OR EDGE OF MORTAR JOINT INTO FACE SHELL OF BLOCK.
- INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS, AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BY THE ANCHOR MANUFACTURER.

WINDSOR WINDOWS & DOORS

CLASSIC FIXED WINDOW (NON-HVHZ)(NON-IMPACT)

INSTALLATION NOTES (CONTINUED):

- INSTALLATION ANCHOR CAPACITIES FOR PRODUCTS HEREIN ARE BASED ON SUBSTRATE MATERIALS WITH THE FOLLOWING PROPERTIES:
 - WOOD - MINIMUM SPECIFIC GRAVITY OF 0.55.
 - CONCRETE -MINIMUM COMPRESSIVE STRENGTH OF 3000 PSI.
 - GROUT-FILLED CMU- UNIT STRENGTH CONFORMS TO ASTM C-90 WITH MINIMUM COMPRESSIVE STRENGTH OF 2000 PSI AND GROUT CONFORMS TO ASTM C 476, MINIMUM GROUT COMPRESSIVE STRENGTH OF 2000 PSI.
 - STEEL - MINIMUM YIELD STRENGTH OF 33 KSI. MINIMUM 18 GA. WALL THICKNESS.
 - ALUMINUM - MINIMUM ALLOY 6063-T5. MINIMUM WALL THICKNESS OF 1/8" (0.125").

GENERAL NOTES:

- THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH THE CURRENT FLORIDA BUILDING CODE (FBC), EXCLUDING HVHZ AND HAS BEEN EVALUATED ACCORDING TO THE FOLLOWING:
 - AAMA/WDMA/CSA 101/I.S.2/A440-11/17
- ADEQUACY OF THE EXISTING STRUCTURAL CONCRETE/MASONRY AND 2X FRAMING AS A MAIN WIND FORCE RESISTING SYSTEM CAPABLE OF WITHSTANDING AND TRANSFERRING APPLIED PRODUCT LOADS TO THE FOUNDATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
- 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO THE STRUCTURE. BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD FOR THE PROJECT OF INSTALLATION.
- THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT IN NON-HVHZ AREAS.
- APPROVED IMPACT PROTECTIVE SYSTEM **IS REQUIRED** ON THIS PRODUCT.
- WINDOW FRAME MATERIAL: VINYL
- GLASS SHALL MEET THE REQUIREMENTS OF ASTM E 1300 GLASS CHARTS. SEE SHEET 3 FOR GLAZING DETAILS.

TABLE OF CONTENTS	
SHEET	SHEET DESCRIPTION
1	INSTALLATION & GENERAL NOTES
2	ELEVATIONS
3	ANCHOR LAYOUTS & GLAZING DETAILS
4	DH BRMLD NAIL FIN INSTALLATION SECTIONS
5	DH BRMLD THRU-FRAME INSTALLATION
6	DH BRMLD CLIP INSTALLATION SECTIONS
7	DH STD NAIL FIN INSTALLATION SECTIONS
8	DH STD THRU-FRAME INSTALLATION
9	DH STD CLIP INSTALLATION SECTIONS
10	SH THRU- FRAME INSTALLATION SECTIONS
11	SH ALTERNATE CLIP INSTALLATION SECTIONS
12	SH STANDARD CLIP INSTALLATION SECTIONS

DESIGN PRESSURE TABLE						
TYP. OVERALL SIZE		DESIGN PRESSURE	CONFIGURATION	FRAME TYPE	INSTALLATION METHOD	MISSILE IMPACT RATING
WIDTH	HEIGHT					
95 1/2"	59 1/2"	+40/-40 PSF	"O"	BRMLD	THROUGH FRAME, NAIL FIN & CLIP	NON - IMPACT
95 1/2"	47 1/2"	+50/-50 PSF	"O"	BRMLD		
95 1/2"	60 1/2"	+50/-50 PSF	"O"	BRMLD		
95 1/2"	60 1/2"	+50/-50 PSF	"O"	SH-BRMLD		
95 1/2"	60 1/2"	+50/-50 PSF	"O"	STD		



WINDSOR WINDOWS & DOORS
900 S. 19TH STREET.
WEST DES MOINES, IA 50265
PH: (515)223-6660 FAX: (515)224-1938

TITLE: CLASSIC FIXED WINDOW (NON HVHZ) (NON-IMPACT)


INSTALLATION AND GENERAL NOTES

PREPARED BY: BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com



REMARKS	BY	DATE


THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL14873

DATE: 11.10.20
DWG. BY: ER
CHK. BY: HFN
SCALE: NTS
DWG. #: WWD059


SHEET: 1 OF 12



TYPICAL ELEVATION
DOUBLE HUNG PICTURE WINDOW
STD FRAME



TYPICAL ELEVATION
DOUBLE HUNG PICTURE WINDOW
BRMLD FRAME




TYPICAL ELEVATION
SINGLE HUNG PICTURE WINDOW
STD FRAME

TITLE: CLASSIC FIXED WINDOW
(NON HVHZ) (NON-IMPACT)
ELEVATIONS

PREPARED BY: **BUILDING DROPS, INC.**
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com


REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL14873

DATE:	11.10.20
DWG. BY:	ER
CHK. BY:	HFN
SCALE:	NTS
DWG. #:	WWD059
SHEET:	2 OF 12




TYPICAL ANCHOR LAYOUT

NAIL FIN INSTALLATION
ALL SIZES




TYPICAL ANCHOR LAYOUT

CLIP OR THROUGH FRAME INSTALLATION
SEE TABLE BELOW FOR O.A. SIZES



GLAZING DETAIL - DH



GLAZING DETAIL - SH

GLAZING NOTES:

- GLASS TYPE & THICKNESS SHALL COMPLY WITH ASTM E1300 REQUIREMENTS AS WELL AS APPLICABLE SAFETY GLAZING REQUIREMENTS PER THE FBC. TEMPER AND SAFETY GLAZING REQUIREMENTS SHALL BE REVIEWED ON A SITE SPECIFIC BASIS.
- SETTING BLOCK DUROMETER HARDNESS OF 70-90 (SHORE A) AS REFERENCED IN FBC CHAPTER 24.
- SETTING BLOCKS TO BE LOCATED AT 1/4 SPAN LENGTH FOR GLASS WIDER THAN 36" AS PER FBC CHAPTER 24.
- DESIGN PRESSURES MAY NOT EXCEED MAX VALUES IN DESIGN PRESSURE TABLES ON SHEET 1.


TYP. OVERALL SIZE		DESIGN PRESSURE	CONFIGURATION	INSTALLATION SYSTEM	
WIDTH	HEIGHT			CLIP	THROUGH FRAME
95 1/2"	59 1/2"	+40/-40 PSF	"O"	16.00"	16.00"
95 1/2"	47 1/2"	+50/-50 PSF	"O"	16.00"	16.00"
95 1/2"	60 1/2"	+50/-50 PSF	"O"	14.00"	14.00"

TITLE:
CLASSIC FIXED WINDOW
(NON HVHZ) (NON-IMPACT)
ANCHOR LAYOUTS
& GLAZING DETAIL

PREPARED BY:
BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HERE IN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873


DATE: **11.10.20**

DWG. BY: **ER** CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **WWD059**


SHEET:




A
4 **VERTICAL SECTION**
DOUBLE HUNG FIXED- BRICKMOULD - HEAD
NAIL FIN INSTALLATION



C
4 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED- BRICKMOULD - JAMB
NAIL FIN INSTALLATION



B
4 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED- BRICKMOULD - SILL
NAIL FIN INSTALLATION



D
4 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED- BRICKMOULD - JAMB
NAIL FIN INSTALLATION

TITLE: CLASSIC FIXED WINDOW (NON HVHZ) (NON-IMPACT)
DH BRMLD NAIL FIN INSTALLATION SECTIONS

PREPARED BY: BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HERE IN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873

DATE: 11.10.20

DWG. BY: ER CHK. BY: HFN


SCALE: NTS

DWG. #: WWD059


SHEET:

4


OF 12




A
5 **VERTICAL SECTION**
DOUBLE HUNG FIXED- BRICKMOULD - HEAD
TRHU- FRAME INSTALLATION



C
5 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED- BRICKMOULD - JAMB
TRHU- FRAME INSTALLATION



B
5 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED- BRICKMOULD - SILL
TRHU- FRAME INSTALLATION




D
5 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED- BRICKMOULD - JAMB
TRHU- FRAME INSTALLATION

TITLE: CLASSIC FIXED WINDOW (NON HVHZ) (NON-IMPACT)
DH BRMLD TRHU- FRAME INSTALLATION SECTIONS

PREPARED BY: BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873


DATE: 11.10.20

DWG. BY: ER CHK. BY: HFN


SCALE: NTS

DWG. #: WWD059


SHEET:




A
6 **VERTICAL SECTION**
DOUBLE HUNG FIXED - BRMLD FRAME - HEAD
ALTERNATE CLIP INSTALLATION



C
6 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - BRMLD FRAME - JAMB
ALTERNATE CLIP INSTALLATION



B
6 **VERTICAL SECTION**
DOUBLE HUNG FIXED - BRMLD FRAME - SILL
STANDARD CLIP INSTALLATION




D
6 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - BRMLD FRAME - JAMB
STANDARD CLIP INSTALLATION

TITLE:
CLASSIC FIXED WINDOW
(NON HVHZ) (NON-IMPACT)
DH BRMLD CLIP INSTALLATION

PREPARED BY:
BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HERE IN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873

DATE: **11.10.20**

DWG. BY: **ER** CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **WWD059**


SHEET:

6


OF 12




A
7 **VERTICAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - HEAD
NAIL FIN INSTALLATION



C
7 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - JAMB
NAIL FIN INSTALLATION



B
7 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - SILL
NAIL FIN INSTALLATION



D
7 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - JAMB
NAIL FIN INSTALLATION


TITLE:
CLASSIC FIXED WINDOW
(NON HVHZ) (NON-IMPACT)

DH STD NAIL FIN
INSTALLATION SECTIONS

PREPARED BY:
BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873

DATE: **11.10.20**

DWG. BY: **ER**

CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **WWD059**


SHEET:

7


OF 12




A
8 **VERTICAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - HEAD
TRHU- FRAME INSTALLATION



C
8 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - JAMB
TRHU- FRAME INSTALLATION



B
8 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - SILL
TRHU- FRAME INSTALLATION



D
8 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - JAMB
TRHU- FRAME INSTALLATION

TITLE:
CLASSIC FIXED WINDOW
(NON HVHZ) (NON-IMPACT)

DH STD TRHU- FRAME
INSTALLATION SECTIONS

PREPARED BY:
BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HEREIN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873

DATE: **11.10.20**


DWG. BY: **ER**

CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **WWD059**


SHEET:




A
9 **VERTICAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - HEAD
ALTERNATE CLIP INSTALLATION



C
9 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - JAMB
ALTERNATE CLIP INSTALLATION



B
9 **VERTICAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - SILL
STANDARD CLIP INSTALLATION




D
9 **HORIZONTAL SECTION**
DOUBLE HUNG FIXED - STD FRAME - JAMB
STANDARD CLIP INSTALLATION

TITLE:
CLASSIC FIXED WINDOW
(NON HVHZ) (NON-IMPACT)
DH STD CLIP INSTALLATION

PREPARED BY:
BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HERE IN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873

DATE: **11.10.20**

DWG. BY: **ER**

CHK. BY: **HFN**


SCALE: **NTS**

DWG. #: **WWD059**


SHEET:

9


OF 12




A
10 **VERTICAL SECTION**
SINGLE HUNG FIXED - HEAD
NAIL FIN INSTALLATION



C
10 **HORIZONTAL SECTION**
SINGLE HUNG FIXED - JAMB
NAIL FIN INSTALLATION



B
10 **HORIZONTAL SECTION**
SINGLE HUNG FIXED - SILL
NAIL FIN INSTALLATION




D
10 **HORIZONTAL SECTION**
SINGLE HUNG FIXED - JAMB
NAIL FIN INSTALLATION

TITLE:
CLASSIC FIXED WINDOW
(NON HVHZ) (NON-IMPACT)
SH NAIL FIN INSTALLATION


PREPARED BY:
BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE


THE INSTALLATION DETAILS DESCRIBED HERE IN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.




FL14873	
DATE: 11.10.20	
DWG. BY: ER	CHK. BY: HFN
SCALE: NTS	
DWG. #: WWD059	
SHEET: 10 OF 12	




A
11 **VERTICAL SECTION**
SINGLE HUNG FIXED- HEAD
TRHU- FRAME INSTALLATION



C
11 **HORIZONTAL SECTION**
SINGLE HUNG FIXED - JAMB
TRHU- FRAME INSTALLATION



B
11 **HORIZONTAL SECTION**
SINGLE HUNG FIXED - SILL
TRHU- FRAME INSTALLATION




D
11 **HORIZONTAL SECTION**
SINGLE HUNG FIXED - JAMB
TRHU- FRAME INSTALLATION

TITLE: CLASSIC FIXED WINDOW (NON HVHZ) (NON-IMPACT)
SH TRHU FRAME INSTALLATION

PREPARED BY: BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HERE IN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873

DATE: 11.10.20

DWG. BY: ER CHK. BY: HFN

SCALE: NTS

DWG. #: WWD059

SHEET:

TITLE: CLASSIC FIXED WINDOW (NON HVHZ) (NON-IMPACT)
SH ALTERNATE CLIP INSTALLATION

PREPARED BY: BUILDING DROPS, INC.
398 E. DANIA BEACH BLVD., STE. 338
DANIA BEACH, FL 33004
PH: (954)399-8478
FAX: (954)744-4738
WEB: www.buildingdrops.com

REMARKS	BY	DATE

THE INSTALLATION DETAILS DESCRIBED HERE IN ARE GENERIC AND MAY NOT REFLECT ACTUAL CONDITIONS FOR A SPECIFIC SITE. IF SITE CONDITIONS CAUSE INSTALLATION TO DEVIATE FROM THE REQUIREMENTS DETAILED HEREIN, A LICENSED ENGINEER OR ARCHITECT SHALL PREPARE SITE SPECIFIC DOCUMENTS FOR USE WITH THIS DOCUMENT.



FL14873

DATE: 11.10.20


DWG. BY: ER CHK. BY: HFN

SCALE: NTS


DWG. #: WWD059

SHEET:


12 OF 12




A
12
VERTICAL SECTION
SINGLE HUNG FIXED - HEAD
STANDARD CLIP INSTALLATION



D
12
HORIZONTAL SECTION
SINGLE HUNG FIXED - JAMB
STANDARD CLIP INSTALLATION



B
12
VERTICAL SECTION
SINGLE HUNG FIXED - SILL
STANDARD CLIP INSTALLATION



C
12
HORIZONTAL SECTION
SINGLE HUNG FIXED - JAMB
STANDARD CLIP INSTALLATION